

WWW.MWFTR.COM

HOMER Input Summary

File name: GreenCampusKU_costdiff.hmr

File version: 2.68 beta

Author: James

Notes: Green Campus in KU

AC Load: Primary Load 1

Data source: Synthetic


Daily noise: 14%

Hourly noise: 10%

Scaled annual average: 143,001 kWh/d

Scaled peak load: 15,445 kW

Load factor: 0.386



PV

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/yr)
10,000.000	25,000,000	2,500,000	25,000

Sizes to consider: 0, 10,000 kW

Lifetime: 20 yr

Derating factor: 80%

Tracking system: No Tracking

Slope: 37.6 deg

Azimuth: 0 deg

Ground reflectance: 20%

Solar Resource

Latitude: 37 degrees 59 minutes North

Longitude: 127 degrees 4 minutes East


Time zone: GMT +9:00

Data source: Synthetic

Month	Clearness Index	Average Radiation
		(kWh/m ² /day)
Jan	0.618	2.830
Feb	0.622	3.700
Mar	0.565	4.450
Apr	0.555	5.420
May	0.506	5.600

Jun	0.429	4.970
Jul	0.348	3.930
Aug	0.405	4.140
Sep	0.475	4.040
Oct	0.535	3.480
Nov	0.559	2.730
Dec	0.608	2.530

Scaled annual average: 3.98 kWh/m²/d




AC Wind Turbine: GE 1.5sl

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/yr)
5	30,000,000	3,000,000	150,000

Quantities to consider: 0, 5, 10

Lifetime: 20 yr

Hub height: 50 m




Wind Resource

Data source: Synthetic

Month	Wind Speed
	(m/s)
Jan	4.09
Feb	4.19
Mar	4.12
Apr	4.17
May	3.75
Jun	3.29
Jul	3.27
Aug	3.09

Sep	3.00
Oct	3.14
Nov	3.70
Dec	3.96



Weibull k: 2.00
 Autocorrelation factor: 0.850
 Diurnal pattern strength: 0.250
 Hour of peak wind speed: 15
 Scaled annual average: 3.7, 7.0, 11.0 m/s
 Anemometer height: 50 m
 Altitude: 0 m
 Wind shear profile: Logarithmic
 Surface roughness length: 0.01 m

Converter

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/yr)
20,000.000	0	0	0

Sizes to consider: 0, 20,000 kW
 Lifetime: 20 yr
 Inverter efficiency: 90%
 Inverter can parallel with AC generator: Yes
 Rectifier relative capacity: 100%
 Rectifier efficiency: 90%

Grid

Rate	Power Price	Sellback Rate	Demand Rate	Applicable
	\$/kWh	\$/kWh	\$/kW/mo.	
Rate W_20.04, 0.50, 1.00, 2.00, 3.00		0.25		0 Jan-Dec All week 00:00-24:00

CO2 emissions factor: 632 g/kWh
 CO emissions factor: 0 g/kWh
 UHC emissions factor: 0 g/kWh
 PM emissions factor: 0 g/kWh
 SO2 emissions factor: 2.74 g/kWh
 NOx emissions factor: 1.34 g/kWh
 Interconnection cost: \$ 0
 Standby charge: \$ 0/yr
 Purchase capacity: 1,000 kW
 Sale capacity: 1,000 kW

Economics

Annual real interest rate: 6%
Project lifetime: 20 yr
Capacity shortage penalty: \$ 0/kWh
System fixed capital cost: \$ 1,000
System fixed O&M cost: \$ 0/yr

Generator control

Check load following: No
Check cycle charging: Yes
Setpoint state of charge: 80%

Allow systems with multiple generators: Yes
Allow multiple generators to operate simultaneously: Yes
Allow systems with generator capacity less than peak load: Yes

Emissions

Carbon dioxide penalty: \$ 0/t
Carbon monoxide penalty: \$ 0/t
Unburned hydrocarbons penalty: \$ 0/t
Particulate matter penalty: \$ 0/t
Sulfur dioxide penalty: \$ 0/t
Nitrogen oxides penalty: \$ 0/t

Constraints

Maximum annual capacity shortage: 100%
Minimum renewable fraction: 0%

Operating reserve as percentage of hourly load: 10%
Operating reserve as percentage of peak load: 0%
Operating reserve as percentage of solar power output: 100%
Operating reserve as percentage of wind power output: 0%