

Lighting Kwang Ahn Bridge by Renewable Energy Sources

Seon Cheol Kim

* On leave from Choong-Nam Industrial High School for 2013-2014 Practical Training at Korea University of Technology Education

Kwang Ahan Bridge located in Pusan City, South Korea,
under illumination supplied by grid power



Input Study

- Load
 - Number of LED lamps: 1184
 - Rated Power of each LED lamp: 10 W
 - Total Lighting Load $1184 \times 10\text{W} = 11840\text{W}$
- Solar Resources
 - Peak Sun Hours: 4
- Wind Resources
 - Average Wind Speed: 6.2 m/s

Renewable Sources

- Wind Turbine: 100KW
- PV: 50KW
- Converter: 50KW

Primary Load Inputs

File Edit Help



Choose a load type (AC or DC), enter 24 hourly values in the load table, and enter a scaled annual average. Each of the 24 values in the load table is the average electric demand for a single hour of the day. HOMER replicates this profile throughout the year unless you define different load profiles for different months or day types. For calculations, HOMER uses scaled data: baseline data scaled up or down to the scaled annual average value.

Hold the pointer over an element or click Help for more information.




Label **Primary Load 1** Load type: ☒ AC ☐ DC Data source: ☒ Enter daily profile(s) ☐ Import time series data file [Import File...](#)

Baseline data

Month **January**

Day type **Weekday**

Hour	Load (kW)
00:00 - 01:00	11.840
01:00 - 02:00	11.840
02:00 - 03:00	11.840
03:00 - 04:00	11.840
04:00 - 05:00	11.840
05:00 - 06:00	11.840
06:00 - 07:00	0.000
07:00 - 08:00	0.000
08:00 - 09:00	0.000
09:00 - 10:00	0.000
10:00 - 11:00	0.000
11:00 - 12:00	0.000



Random variability

Day-to-day **15** %

Time-step-to-time-step **20** %

Scaled annual average (kW/h/d) **141** { }

	Baseline	Scaled
Average (kW/h/d)	141	141
Average (kW)	5.88	5.87
Peak (kW)	22.8	22.8
Load factor	0.257	0.257

[Efficiency Inputs...](#)

[Plot...](#)

[Export...](#)

[Help](#)

[Cancel](#)

[OK](#)

Wind Turbine Inputs

File Edit Help



Choose a wind turbine type and enter at least one quantity and capital cost value in the Costs table. Include the cost of the tower, controller, wiring, installation, and labor. As it searches for the optimal system, HOMER considers each quantity in the Sizes to Consider table.

Hold the pointer over an element or click Help for more information.

Turbine type Details... New... Delete


Turbine properties

Abbreviation: FL100 (used for column headings)

Rated power: 100 kW AC

Manufacturer: Fuhrl?der AG

Website: www.fuhrlaender.de




Costs

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/yr)
1	11000	7000	200
2	20000	12000	375
	{.}	{.}	{.}

Sizes to consider

Quantity
0
1
2



Other

Lifetime (yrs) {.}

Hub height (m) {.}

Help

Cancel

OK

PV Inputs

File Edit Help



Enter at least one size and capital cost value in the Costs table. Include all costs associated with the PV (photovoltaic) system, including modules, mounting hardware, and installation. As it searches for the optimal system, HOMER considers each PV array capacity in the Sizes to Consider table.

Note that by default, HOMER sets the slope value equal to the latitude from the Solar Resource Inputs window.

Hold the pointer over an element or click Help for more information.


Costs

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/yr)
50.000	6900	6900	0

{.}

Sizes to consider

Size (kW)
0.000
100.000
200.000



Properties

Output current ☐ AC ☒ DC

Lifetime (years) {.}

Derating factor (%) {.}

Slope (degrees) {.}

Azimuth (degrees W of S) {.}

Ground reflectance (%) {.}

Advanced

Tracking system

☐ Consider effect of temperature

Temperature coeff. of power (%/°C) {.}

Nominal operating cell temp. (°C) {.}

Efficiency at std. test conditions (%) {.}

Help

Cancel

OK

PV Inputs

File Edit Help



Enter at least one size and capital cost value in the Costs table. Include all costs associated with the PV (photovoltaic) system, including modules, mounting hardware, and installation. As it searches for the optimal system, HOMER considers each PV array capacity in the Sizes to Consider table.

Note that by default, HOMER sets the slope value equal to the latitude from the Solar Resource Inputs window.

Hold the pointer over an element or click Help for more information.


Costs

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/yr)
50.000	6900	6900	0

{.}	{.}	{.}
-----	-----	-----

Sizes to consider

Size (kW)
0.000
100.000
200.000



Properties

Output current ☐ AC ☒ DC

Lifetime (years) {.}

Derating factor (%) {.}

Slope (degrees) {.}

Azimuth (degrees W of S) {.}

Ground reflectance (%) {.}

Advanced

Tracking system

☐ Consider effect of temperature

Temperature coeff. of power (%/°C) {.}

Nominal operating cell temp. (°C) {.}

Efficiency at std. test conditions (%) {.}

Help

Cancel

OK

Battery Inputs

File Edit Help



Choose a battery type and enter at least one quantity and capital cost value in the Costs table. Include all costs associated with the battery bank, such as mounting hardware, installation, and labor. As it searches for the optimal system, HOMER considers each quantity in the Sizes to Consider table.

Hold the pointer over an element or click Help for more information.

Battery type **Surrette 6CS25P**

Details...

New...

Delete

Battery properties

Manufacturer: Rolls/Surrette

Website: www.rollsbattery.com

Nominal voltage: 6 V

Nominal capacity: 1,156 Ah (6.94 kWh)

Lifetime throughput: 9,645 kWh

Costs

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/yr)
1	6000	6000	50.00

{..}

{..}

{..}


Advanced

Batteries per string (6 V bus)

☐ Minimum battery life (yr) {..}

Sizes to consider

Batteries
0
30
60
90



Help

Cancel

OK

HOMER - [Project1windPV.hmr]

File

View

Inputs

Outputs

Window

Help

Equipment to consider

Add/Remove...

Fuhr?der 100

AC

Primary Load 1

141 kWh/d

23 kW peak

DC

PV

Converter

S6CS25P

Resources

Other

Solar resource

Wind resource

Economics

System control

Emissions

Constraints

Document

Author

Notes

Calculate

Simulations: 0 of 144

Progress:

Sensitivities: 0 of 15

Status:

Sensitivity Results

Optimization Results

Sensitivity variables

CO2 Penalty (\$/t) 1

Max. CO2 Emissions (kg/yr) 10,000

Double click on a system below for

	PV (kW)	FL100	S6CS25P	Conv. (kW)	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shorta...
		1	60	50	\$ 383,250	17,683	\$ 572,012	1,056	1,00	0,02
	100	1	60	50	\$ 397,050	17,819	\$ 587,262	1,071	1,00	0,00
	200		90	50	\$ 579,850	26,178	\$ 859,296	1,575	1,00	0,01

Completed in 14 seconds.

System Report - Project1

Sensitivity case


CO2 Emissions Penalty: 2 \$/t
 Maximum CO2 Emissions: 30,000 kg/yr

System architecture

Wind turbine 1	Fuhrlander 100
Battery	60 Surrette 6CS25P
Inverter	50 kW
Rectifier	50 kW

Cost summary

Total net present cost	\$ 572,012
Levelized cost of energy	\$ 1.056/kWh
Operating cost	\$ 17,683/yr




Net Present Costs

Component	Capital (\$)	Replacement (\$)	O&M (\$)	Fuel (\$)	Salvage (\$)	Total (\$)
Fuhrlander 100	11,000	2,207	2,135	0	-341	15,001
Surrette 6CS25P	360,000	199,733	32,024	0	-48,186	543,571
Converter	6,250	1,341	534	0	-684	7,440
Other	6,000	0	0	0	0	6,000
System	383,250	203,280	34,693	0	-49,211	572,012

Annualized Costs

Component	Capital (\$/yr)	Replacement (\$/yr)	O&M (\$/yr)	Fuel (\$/yr)	Salvage (\$/yr)	Total (\$/yr)
Fuhrlander 100	1,030	207	200	0	-32	1,405
Surrette 6CS25P	33,724	18,711	3,000	0	-4,514	50,921
Converter	585	126	50	0	-64	697
Other	562	0	0	0	0	562
System	35,902	19,043	3,250	0	-4,610	53,585


Surrette 6CS25P	33,724	18,711	3,000	0	-4,514	50,921
Converter	585	126	50	0	-64	697
Other	562	0	0	0	0	562
System	35,902	19,043	3,250	0	-4,610	53,585



Electrical

Component	Production (kWh/yr)	Fraction
Wind turbine	268,724	100%
Total	268,724	100%

Wind Power Alone works






Load	Consumption (kWh/yr)	Fraction
AC primary load	50,746	100%
Total	50,746	100%

Quantity	Value	Units
Excess electricity	204,508	kWh/yr
Unmet load	719	kWh/yr
Capacity shortage	853	kWh/yr
Renewable fraction	1.000	

AC Wind Turbine: Fuhrlander 100

Variable	Value	Units
Total rated capacity	100	kW
Mean output	30.7	kW
Capacity factor	30.7	%



Quantity	Value	Units
Energy in	29,517	kWh/yr
Energy out	23,618	kWh/yr
Storage depletion	5.48	kWh/yr
Losses	5,893	kWh/yr
Annual throughput	26,406	kWh/yr
Expected life	12.0	yr



Converter

Quantity	Inverter	Rectifier	Units
Capacity	50.0	50.0	kW
Mean output	2.4	3.4	kW
Minimum output	0.0	0.0	kW
Maximum output	21.6	14.8	kW
Capacity factor	4.9	6.7	%

Quantity	Inverter	Rectifier	Units
Hours of operation	2,349	6,200	hrs/yr
Energy in	23,618	34,726	kWh/yr
Energy out	21,257	29,517	kWh/yr
Losses	2,362	5,209	kWh/yr



Emissions


Pollutant	Emissions (kg/yr)
Carbon dioxide	0
Carbon monoxide	0
Unburned hydrocarbons	0
Particulate matter	0
Sulfur dioxide	0
Nitrogen oxides	0


Optimization

- Wind Turbine 100KW
- Installation of 50KW at either side of the bridge.

Diesel Generator Only Case

- Gen1-200KW
- CO₂ Emission 89,931 kg/yr





Simulation Results

System Architecture: 50 kW Generator 1

Total NPC: \$ 629,645

Levelized COE: \$ 1.146/kWh

Operating Cost: \$ 58,188/yr

Cost Summary | Cash Flow | Electrical | Label | Emissions | Hourly Data

Cost type:

☒ Net present

☐ Annualized

☒ Reverse sign


Categorize:

☒ By component

☐ By cost type

☐ Show details

Compare...



Component	Capital (\$)	Replacement (\$)	O&M (\$)	Fuel (\$)	Salvage (\$)
Generator 1	2,500	6,979	2,337	583,285	-256
Other	6,000	0	28,800	0	0
System	8,500	6,979	31,137	583,285	-256

XML Report

HIML Report

Help

Close

HOMER - [Project1 *]

File View Inputs Outputs Window Help

Equipment to consider: Add/Remove... Calculate

Generator 1 → Primary Load 1
141 kWh/d
23 kW peak

Resources: Diesel AC Other

Economics
System control
Emissions
Constraints

Document

Author

Notes

Sensitivity Res
Sensitivity vari
CO2 Penalty (\$/t)
Double click on
Label (kW)
50

System Report - Project1

Sensitivity case


CO2 Emissions Penalty: 30 \$/t
Maximum CO2 Emissions: 1,000,000 kg/yr

System architecture

Generator 150 kW

Cost summary

Total net present cost	\$ 629,645
Levelized cost of energy	\$ 1.146/kWh
Operating cost	\$ 58,188/yr




Net Present Costs


Component	Capital (\$)	Replacement (\$)	O&M (\$)	Fuel (\$)	Salvage (\$)	Total (\$)
Generator 1	2,500	6,979	2,337	583,285	-256	594,845
Other	6,000	0	28,800	0	0	34,800
System	8,500	6,979	31,137	583,285	-256	629,645

Annualized Costs

Component	Capital (\$/yr)	Replacement (\$/yr)	O&M (\$/yr)	Fuel (\$/yr)	Salvage (\$/yr)	Total (\$/yr)
Generator 1	234	654	219	54,641	-24	55,724
Other	562	0	2,698	0	0	3,260
System	796	654	2,917	54,641	-24	58,984



Completed in 4 seconds.



Conclusions

- Kwang Ahn Bridges can be illuminated at night by using 100KW wind turbine power.

