8. Modeling using HOMER – Part 2

Practice 2 & Grid-Connected Micropower System

Charles Kim, "Lecture Note on Analysis and Practice for Renewable Energy Micro Grid Configuration," 2013. www.mwftr.com

1

Course Contents and Schedule

Day 4

HOMER Simulation 2

⊠Grid Data Details

⊠Grid-Connected System Design

Team Practice

⊠Isolated or **Grid-Connected** Power System Design


🔀 Day 5

⊠Team Presentation

⊠Summary and Conclusions

On SWERA

- 2001: The Solar and Wind Energy Resource Assessment (SWERA)
 - began with support from the Global Environment Facility within the United Nations Environment Program (UNEP) with contributions by many national agencies.
 - SWERA was initially a country-centric project focused on the production of National Solar and Wind Assessments supporting renewable energy decision makers in 13 countries within a global framework that included several continental datasets.
 - Ethiopia, Kenya, Ghana, Bangladesh, China, Nepal, Sri Lanka, Brazil, Cuba, El Salvador, Guatemala, Hondurans, and Nicaragua



Company United Nations Environment

National Renewable Energy Laboratory, German Aerospace Center (DLR), Risoe National Laboratory for Sustainable Energy, Brazil's National Institute for Space
Partner Research (INPE), State University of New York (SUNY), Technical University of Denmark (DTU), UNEP Global Resource Information Database (UNEP/GRID), NASA, Global Environment Facility (GEF)
Sector Energy
Focus Area Solar, Wind
Topics Resource assessment, Pathways analysis
Resource Type Software/modeling tools, Maps, Dataset
User Interface Website
Website http://openei.org/SWERA

SWERA

- 2005: support from NASA, SWERA began the transition into a global decision support system (DSS) with integrated tools including prototype small hydropower assessments to complement the solar and wind assessments.
 - NASA global renewable energy assessments and climate data were integrated into SWERA to provide global coverage and a more complete portfolio of information needed to assess the global renewable energy potential.
 - United States National Renewable Energy Laboratory (NREL) contributed renewable energy expertise and 27 national data sets.

Data Set



- Bata obtained from the NASA Science Mission Directorate's satellite and re-analysis research programs
- # Parameters were validated based on recommendations from partners in the energy industry
- Continued to adapt and tailor updated and new data sets from NASA's satellite observation analysis and modeling program.
- He Clouds and Earth's Radiant Energy System (CERES) computes the most accurate global surface radiation fluxes using radiance and retrievals to date. These fluxes include the computation of direct and diffuse fluxes.
- 8 Other data: tilt irradiance, direct normal irradiance, global horizontal irradiance, wind, relative humidity, atmospheric pressure, air temperature, etc.
- ₭ For Solar, NASA data exist for 22 years globally.
- How With State State

HOMER practice 2: Making a New file from scratch

- ₩ HOMER
- ₭ File > New
- ₭ Click "Add/Remove"

	HOMER - [Pr	oject1 *]				File View 1	Inputs Out	puts Window
M	File View	Inputs	Outputs	Window	He	🗅 🛩 🖬 🗟 🛙	🖩 📓 😭 🗊	?
D	New			Ctrl+N	1	Equipment to consider -	[Add/Remove
È	Open	15		Ctrl+O				
	Close							· \ ₽
	Save			Ctrl+S	Se		the Add/Remove to add loads an	
	Save As					c	components.	

Select: Primary Load, PV, Wind Turbine 1, Converter, and Generator1

old the pointer over an element or click Help for mor	e information.		
Loads	– Components –		
💡 🔽 Primary Load 1	🛷 🔽 PV	📛 🔽 Generator 1	🖽 🔽 Battery 1
😰 🦵 Primary Load 2	🗼 🔽 Windside 4A	🔄 🦵 Generator 2	🗐 🥅 Battery 2
🧟 🥅 Deferrable Load	🧍 🗔 Wind Turbine 2	🖧 🦵 Generator 3	🗂 🥅 Battery 3
🍊 🦵 Thermal Load 1	🛱 🥅 Hydro	🗁 🦵 Generator 4	🗐 🥅 Battery 4
🍊 🦵 Thermal Load 2	🖾 🔽 Converter	🔄 🦵 Generator 5	🗐 🥅 Battery 5
💝 🥅 Hydrogen Ioad	👶 🦵 Electrolyzer	🗁 🦵 Generator 6	🗐 🥅 Battery 6
	🧐 🥅 Hydrogen Tank	🖧 🦵 Generator 7	🗐 🥅 Battery 7
	🗯 厉 Reformer	🗁 🦵 Generator 8	🗐 🥅 Battery 8
		🗁 🦵 Generator 9	🗂 🥅 Battery 9
		🖧 🥅 Generator 10	🗂 🦳 Battery 10
	Grid		
	On not model grid		
	A ⊂ System is connected to	grid ystem to grid extension	


Load Data

Equipment to consider

2

Generator 1

- **HOMER** buttons appear
- H NOW click the load button
- How Type in the load [kW] every hour period



7

Add/Remove.

Windside 4A

Primary Load 1

~

Converter

Load Profile Example

H Load Data Example Small Commercial Load Profile [kW] 0000 0100 0200 0300 0400 0500 0600 0700 0800 0900 1000 1100 1.31 1.30 1.27 1.27 1.30 1.39 1.54 1.67 1.90 2.18 2.33 2.36 1200 1300 1400 1500 1600 1700 1800 1900 2000 2100 2200 2300 2.35 2.31 2.31 2.33 2.37 2.28 1.98 1.86 1.81 1.64 1.43 1.33 Daily Total [kW]44.60 Stret Light Load Profile [kW] 0000 0100 0200 0300 0400 0500 0600 0700 0800 0900 1000 1100 3,24 3 24 3,24 3,24 3,24 2,62 1,40 0,18 1,90 0,00 0,00 0,00 1200 1300 1400 1500 1600 1700 1800 1900 2000 2100 2200 2300 $0.00 \ 0.00 \ 0.00 \ 0.00 \ 0.00 \ 0.42 \ 0.88 \ 1.28 \ 2.47 \ 3.24 \ 3.24 \ 3.24$

Alternative way for Solar and Wind Resources ---Import XLM File from SWERA

% 1. Find Lat & Lon of your location

2. On SWERA

- Type in Lat & Long
- Click "Get Homer"
- From the XLM data screen
 CTRL+S (save to an XLM file)

∺ 3. Now with HOMER

- ➢ File>"Import XLM"
- Wind Resources are automatically filled
- Solar Resources are automatically filled
 - ⊠Lat N, Long E \rightarrow marking error ⊠But kWh/m2 is kept the same.

	HOMER - [Practice2.h	mr]	
	File View Inputs	Outputs Window	Help
	New	Ctrl+N	
;	Open	Ctrl+O	
	Close	1	
	Save	Ctrl+S	Sensitivity
	Save As	II	Sensitivity
	Import XML		Graph type Variables
T	Export XML		-
			Primary F
	HTML Input Summary		2.0
	Compare File		
	1 Practice2.hmr		-
	2 C:\E_2013\\yenhwa.hmr	II	-
	3 C:\E_2013\\neopower.hn	nr	1.5-
	4 Privacy for Tibebu.hmr	II	s
	5 C:\E_2013\\Mongolia.hm	ır –	N.
	6 GreenCampusKU_costdif	f.hmr	acity
	7 C:\E_2013\\neopowerDC	G12.hmr	<mark>ਉ</mark> 1.0
	8 yenhwaprj(PT).hmr		РV Аптау Capacity (kW)
ł	Preferences		PV
	Exit		0.5

How about Load Profile for this Mobile Security on Demand?

Mobile security: 2 PV, 4 cameras, Digital recording, battery charger circuits, battery status of charge monitoring and wireless alerting.



Generator Information

aupment to conside

Generator


- Now arrow appearsfrom AC bus to load
- ₭ Click "Generator"
- ₭ Size: 5.0 kW
- 8 Capital: \$2000
- ₭ Replacement: \$2000
- ₩ O&M: \$0.02/hr
- Sizes to consider:0, 2.5kW, 5.0kW
- Minimum loadcapacity: 30%

Converter	Windside 4A
	naintenance (D&M) value in the Costs table. Note that the capital cost includes g hour. Enter a nonzero heat recovery ratio if heat will be recovered from this generator nsider each generator size in the Sizes to Consider table.
Cost Fuel Schedule Emissions Costs	Sizes to consider
	Help Cancel 11 OK

Add/Remove...

Primary Load 1 43 kWh/d

4.4 kW peak



Wind Resources

Click Wind Resources Button

Location of your choice

- Your side of street lights
- Your (future) vacation home

% Find Latitude and Longitude

- Find Wind Speed [m/s] using SWERA or WINDFINDER
- ₭ Type in the speed



	control how	•	ata: baseline 1760 hourly	e data s values i	caled up from the	or down 12 month	to the so	aled ann	iual avei	r the ave rage valu	rage win e. The a	d speed I dvanced	or each paramel	month. Fi ers allow	or you to
	ta source:	 Enter monthly ave 				me seri	ies dati	a file		Import	File				
Bas	seline data -	Wind Speed													
	Month -	(m/s)	1.0 -		2 2				Wind R	esource		2			
	January	0.000													
	February	0.000	(s).8 (s),(u) peeds 0.4 pu M 0.2				-					1			
	March	0.000	E 0.6-												
	April	0.000	000												
	May	0.000	0.4- 0										-		
	June	0.000	Ĕ 0.2.												
	July	0.000	- 0.2					1							
	August	0.000	0.0	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
	September	0.000		Jan	reu	war	Abi	way	3011	JUI	Aug	Seh	ou	NOV	DeC
	October	0.000	Other p	aram	eters -					Advanc	ed par	ameter	's		
	November	0.000							-		8			1	-
	December	0.000	Altitu	de (m	above	sea lev	/el)		0	Weib	oull k				2
			Anen	nomet	er heig	ht (m)	Γ	8	10	Auto	correla	tion fac	tor		0.85
				Vi	ariation	With H	eiaht	i.		Dium	ial patti	ern stre	ngth	-	0.25
	Annual av	erage: 0.000					9/100			Hour	of pea	k winds	peed		15
	Scaled an	nual average (m/s)		0	(.) [Plot.	1	E	art	1	
	200.00 000				0.0				_	Piùt.	•	Exp	ort		
										Help		Ca	Selute.	13	OK

PV Information

- ₩ Click "PV"
- Size: 2kW
- **#** Capital: \$7000
- Replacement:\$7000
- ₩ O&M: \$0/yr
- Sizes to consider: 0, 2kW, 4kW

Ħ


PŸ		
nputs		-
e Edit Help		
Enter at least on size and capital cost value in the Cost hardware, and installation. As it searches for the optimal	sts table. Include all costs associated with the PV (photovoltaic) system, including I system, HOMER considers each PV array capacity in the Sizes to Consider table.	modules, mounting
Note that by default, HOMER sets the slope value equa		
Hold the pointer over an element or click Help for more in	information.	
osts		Curve
Size (kW) Capital (\$) Replacement (\$) 0&M (\$/yr) 2.000 7000 0	Size (kW) 14 0000 12 0000	
2.000 1000 1000 0		
{.} {.}	{}	
	2	
perties	o i	2 3 4
	- Craitel -	
· · · · · · · · · · · · · · · · · · ·		 Replacement
fetime (years) 20 {}	Advanced	Replacement
fetime (years)		
fetime (years) 20 {} erating factor (%) 80 {}	Advanced	
fetime (years) 20 {} erating factor (%) 80 {} lope (degrees) 0 {}	Advanced Tracking system No Tracking	.
ifetime (years) 20 {} Derating factor (%) 80 {} Slope (degrees) 0 {}	Advanced Tracking system No Tracking Consider effect of temperature	5
ifetime (years) 20 {} berating factor (%) 80 {} clope (degrees) 0 {} szimuth (degrees W of S) 0 {}	Advanced Tracking system No Tracking Consider effect of temperature Temperature coeff. of power (%/*C)	• 5 <u>{.}</u> 7 <u>{.}</u>

Solar Resources Information

Solar Resour	ce Inputs								
File Edit	and the state of the		_						
Hold	5	x for each month. HOME n element or click Help fo			average daily radiatior	n from the clearne:	ss index and vice-ve	ersa.	
Location -	· · ·	0 ' @ North	C South	Time zone					-
Latitude		• North		TIME ZONE					
	e: (Entermo		C West	(GMT) Iceland, e series data file	UK, Ireland, West			•	
	e: (Entermo	onthly averages Daily Radiation	C West	1		a Internet		–	L.)
Data source Baseline da	e: (Enter mo	onthly averages Daily Radiation (kWh/m2/d) 2.8	C West C Importtime	1	Get Data Via	a Internet			-
Data source Baseline da Month January February	e: (Enter mo	onthly averages Daily Radiation (KWh/m2/d) 2.8 3.6	C West C Import time	1	Get Data Via	a Internet			-
Data source Baseline da Month January February March		Daily Radiation (KWh/m2/d) 3.6 4.4	C West C Import time	1	Get Data Via	a Internet		1.0	-
Data source Baseline da Month January February March April	e: (Enter mo	Daily Radiation (kWh/m2/d) 2.8 3.6 4.4 5.4	C West C Import time	1	Get Data Via	a Internet		1.0	-
Data source Baseline da Month January February March	Clearness Index 0.280 0.355 0.427 0.529	Daily Radiation (kWh/m2/d) 2.8 3.6 4.4 5.4	C West C Import time	1	Get Data Via	a Internet		1.0	
Data source Baseline da Month January February March April May	E Enter mo tta Clearness Index 0.280 0.355 0.427 0.529 0.577	Daily Radiation (kWh/m2/d) 2.8 3.6 4.4 5.4 5.5 4.3	C West C Import time 320 5 490 5 490 5 400 4 400 4 400 5 390 5	1	Get Data Via	a Internet		1.0 -0.8 -0.6 c	
Data source Baseline da Month January February March April May June	Clearness Clearness Index 0.280 0.355 0.427 0.529 0.577 0.536 0.442 0.423	Daily Radiation (kWh/m2/d) (kWh/m2/d) 2.8 3.6 4.4 5.5 5.5 4.9 4.1 4.1	C West C Importtime	1	Get Data Via	a Internet		1.0	
Data source Baseline da Month January February March April May June July August Septemt	Enter mo ta Clearness Index 0.280 0.355 0.427 0.529 0.577 0.536 0.442 0.423 mer 0.382	Daily Radiation (kWh/m2/d) (kWh/m2/d) 2.8 3.6 4.4 5.5 4.9 4.1 4.1 3.9	C West C Import time (C Import time	1	Get Data Via	a Internet		1.0 -0.8 -0.6 c	
Data source Baseline da Month January February March April May June July August Septemt October	E Clearness Index 0.280 0.355 0.427 0.529 0.577 0.536 0.442 0.442 0.423 mer 0.382 0.343	Daily Radiation (kWh/m2/d) 2.8 3.6 4.4 5.5 4.3 4.1 4.1 3.9 3.5	C West C Import time	1	Get Data Via	a Internet		1.0 -0.8 -0.6 c	
Data source Baseline da Month January February March April May June July August Septemt	e:	Daily Radiation (kWh/m2/d) (kWh/m2/d) 2.8 3.6 4.4 5.5 4.9 4.1 4.1 3.9 3.5 2.7	C West C Import time (C Import time	1	Get Data Via	a Internet		1.0 -0.8 -0.6 xppr -0.4 ppr -0.4 ppr	

Converter Information

- \approx Converter (DC \rightarrow AC)
- K Size: 1kW
- 800 Capital: \$800
- ₩ O&M: \$0
- Sizes to consider: 0, 1, 2 kW



onverter Inputs	
ile Edit Help	
both. Enter at least one size and capital cost value in the Costs table. Include	C load or vice-versa. A converter can be an inverter (DC to AC), rectifier (AC to DC), or all costs associated with the converter, such as hardware and labor. As it searches for izes to Consider table. Note that all references to converter size or capacity refer to
Costs	Sizes to consider —
Size (kW) Capital (\$) Replacement (\$) 0&M (\$/yr)	Size (kW) 1,600 Cost Curve
1.000 800 800 0	0.000 1.200
[] {] {]	2000 2000
Lifetime (years)	- Capital - Replacement
Efficiency (%) 90 {.}	
✓ Inverter can operate simultaneously with an AC generate	r
Rectifier inputs	
Capacity relative to inverter (%) 100 {} Efficiency (%) 85 {}	
·	Help Cancel OK

16

Diesel Resources Information

		Resources —	- Other
Fuel Price: \$0.8/L		Solar resource	Economics
		Wind resource	System control
B Sensitivity Price: \$0.8, 1.6, 2.4/L		Diesel	Emissions
Simulatione: 144 of 144	Drogroce:		🗾 Constraints
Diesel Inputs	Company Company		
File Edit Help			
Enter the fuel price. The fuel properties can only be changed when creating a the Generator Inputs or Boiler Inputs window).	new fuel (click New in		
Hold the pointer over an element name or click Help for more information.	Sensitivity Values		
Price (\$/L) 0.8 {.} Limit consumption to (L/yr) 5000 {.} Fuel properties	Variable: Diesel Price Units: \$/L Link with: Values: 1 0.800 2 1.600 3 2.400 4 5 6 7 8 9 10 11 12 10 11 12 10 11 12		
	Help	Cancel	ОК

Emission Information

- **₭** CO2: \$3/ton
- **# CO: \$0**


C02: Sensitivity Data {0, 1, 2, 3}

Outputs window Her	þ					- 0'
	nissions Inputs					
Add/Remove	ile Edit Help					
d1 J ak	Costs resulting from emissions penalties appear as 'O systems that exceed the specified emissions limits. Hold the pointer over an element or click Help for mo	/	cards Sensitivity Valu	ues	1.0	and light
r Windside 4A	Emissions penalties Carbon dioxide (\$/t)	3	Variable: Units:	CO2 Emissions Pi \$/t	enalty	
DC ner	Carbon monoxide (\$/t)	0 {}	Link with:	<none></none>		-
Economics	Unburned hydrocarbons (\$/t)	0 {}	Values:	1 3.00	▲ Clear	1
System control	Particulate matter (\$/t)	0 {}		2 2.00 3 1.00		-
	Sulfur dioxide (\$/t)	3 {}		4 0.00 5		
	Nitrogen oxides (\$/t)	3 {.}		6		
	Limits on emissions		-	8		
	🥅 Carbon dioxide (kg/yr)	0 {}		9 10		
	🥅 Carbon monoxide (kg/yr)	0 {}		11 12	*	
	🥅 Unburned hydrocarbons (kg/yr)	0 {}				
	🦳 Particulate matter (kg/yr)	0 {}		Help	Cancel	ОК
	🔲 Sulfur dioxide (ka/vr)	0 {}	<u></u>			


Simulation

H

H




Sensitivity Analysis



HOMER – Input Summary Report


- **HOMER Produces An Input Summary Report:**
 - Click HTML Input Summary from the File menu, or click the toolbar button:
 - HOMER will create an HTML-format report summarizing all the relevant inputs, and display it in a browser. From the browser, you can save or print the report, or copy it to the clipboard so that you can paste it into a word processor or spreadsheet program.



HOMER – Simulation Result Report

HOMER Produces A Report Summarizing The Simulation Results

Just click the HTML Report button in the Simulation Results window:



What is this message for?



PV search space may be insufficient.

Converter search space may be insufficient.


Dompleted in 3:17.



- **#** Those messages mean that:
 - you need to expand your search space to be sure you have found the cheapest system configuration.
 - If the total net present cost varied with the PV size in this way, and you simulated 10, 20, 30, and 40 kW sizes, HOMER would notice that the optimal number of turbines is 40 kW, but since that was as far as you let it look, it would give you the "search space may be insufficient" warning because 50 kW may be better yet.
 - \square It doesn't know that until you let it try 50kW and 60kW.
 - If you expanded the search space, HOMER would no longer give you that warning, since the price started to go up so you have probably identified the true least-cost point.


HOMER: Grid-Connected Micro-Power system

- Place: A commercial/retail in Seoul/Cheonan/Byungchon
- His project investigates the options for providing electricity to the commercial/small store using wind, solar, or diesel power.
- It also analyzes the impact of different assumptions about the wind resource, fuel price, and required system reliability.
- Solar Resources: Actual data via Internet
- Wind Resources: Wind speed data
- K Load: 35kWh/d and 4.5 kW peak



Components and Constraints

- **Components:**
 - PV: Default performance: 1kW [0, 2, 4 kW]
 - Wind Turbine: 3kW [Qty 0 1 2 3]
 - Diesel Generator: 5 kW is considered (peak load is 4.5 kW)
 - ⊠ Fuel: \$0.3/L [0.3, 0.5, 0.7]
 - ⊠ Limit Consumption: 5000 L/year
 - Batteries: Marine Battery [6V, 1167 Ah] [0 10 20 30]
 - Inverter: 10kW size. (cost: \$1250/kW) [0, 2, 4, 6, 8 kW]
 - Grid: Single rate at \$0.15/kWh; Sellback at \$0.15/kWh; Demand Charge at \$5.0/kW/month
- **#** Economics:
 - Real interest rate: 8%
 - Project lifetime: 25 years
 - System fixed capital cost: \$6000
 - ☑ It represents balance of system and distribution system costs that cannot be allocated to a specific component.
- **Reliability**:
 - Maximum Annual Capacity Shortage: 0% [0.0, 0.1]



Solar Resources

K Latitude, Longitude, Time Zone, Get Data of **your location**

average	clearness index	resource inputs to calculate th (for each month, HOMER us) element or click Help for mor	es the latitud	de value											ie or an	
on	-	6														-
itude	37 •	0 · @ North C	South	Tim	ne zoni	e									1	-
ngitude	127 •	0 · @ East C		(G	MT+09	9:00) Ja	apan, I	North	Korea	, South K	orea			-	-	
source: ine data		Daily Radiation	Import tim							a Internet						
Month	Liearness Daily Radiation			1	1	1						1		1	1.0	1.0
anuary	0.477	2.264														
ebruary	0.467	2.851	5-	-	-				-				-		-0.8	
1arch	0.497	3.966	(p/2												_	
.pril	0.533	5.243	Ę 4-					-	-					_	-	×
tay	0.522	5.777	(KM												0.6	xepul
une	0.491	5.681	63-	_							_					888
uly	0.455	5.135	Radiation (kWh/m³/d) 6 1													Clearness
ugust	0.503	5.161	Rai		8 10		1 2	8 1		0 0 0 000					0.4	Cle
eptember	0.516	4.436	d ally P													
•	0.530	3.524													-0.2	
Ictober			1-												-	
•	0.475	2.056														
Ictober	0.512 0.475	2.582 2.056	1-	Jan	Feb	Mar	Apr	May	Jun	Jul A	Aug S		et No	ov Dec	0.0	

28

Wind Resources

Type in Wind Speed Data

Wind Resource Inputs $f(v) = \frac{k}{c} \left(\frac{v}{c}\right)^{k-1} \exp\left[-\left(\frac{v}{c}\right)^{k}\right]$ File Edit Help HOMER uses wind resource inputs to calculate the wind turbine power each hour of the year. Enter the average wind speed for **وک** calculations, HOMER uses scaled data: baseline data scaled up or down to the scaled annual average value. The advanced pa control how HOMER generates the 8760 hourly values from the 12 monthly values in the table. Hold the pointer over an element or click Help for more informati File View Inputs Outputs Window Help Data source: (Enter monthly averages C Import time series data file Import File.. Baseline data Wind Speed Wind Resource Month (m/s)4.700 January od (m/s) 4.900 February 4.700 March 4.100 April ds 2 3.600 pull 1 May 3.400 June 3.400 July 0 3.800 August May Feb Mar Apr Jun Jul Aug Sep Oct Nov Dec September 3.500 Other parameters Advanced parameters 3.300 October 3.700 November 0 2 Altitude (m above sea level) Weibull k 4.200 December Anemometer height (m) 10 Autocorrelation factor 0.85 0.25 Diurnal pattern strength Variation With Height... Hour of peak windspeed 14 Annual average: 3.937 3 {3} Scaled annual average (m/s) Plot... Export... Help Cancel OK

The diurnal pattern strength simply indicates how strongly the wind speed depends on the time of day. If the wind speed tends to peak at the same time as the load, then a strong daily pattern would be a good thing. It would mean the wind blows when you need the power. If the wind speed peak was out of sync with the load peak, then a strong daily pattern would be a negative.

Diesel Resources

₭ \$0.5/L₭ Sensitivity: [\$0.3, 0.5, 0.7]/L

Diesel Inputs			The same	-		(4—10)
File Edit Help						
Enter the fuel price. The fuel properties can only be the Generator Inputs or Boiler Inputs window). Hold the pointer over an element name or click He			a new fuel (click New in			
Price (\$/L)	0.3	{3}	—			
✓ Limit consumption to (L/yr)	5000	{}	Sensitivity Value	s		
Fuel properties Lower heating value:	43.2 MJ/		Variable: D Units: \$/			
Density: Carbon content:	820 kg/i 88 %	ns	Link with:	none>		•
Sulfur content:	0.33 %	~	Values:	1 0.300 2 0.500		Clear
	Help	Cano		3 0.700 4 5 6	-	

Component: Load Input

₭ Type in hourly load [kW]

೫ [0000 − 1200]: 2, 2, 2, 2, 2, 7, 7, 2, 2, 4, 4, 7 kW

₭ [1300 - 0000]: 7, 7, 8, 8, 8, 12, 12, 12, 12, 12, 8, 8 kW

Primary Load	Inputs							
File Edit	Help							
	ER replicates thi d annual averag	is profile thro je value.	nter 24 hourly valu bughout the year u or click Help for m	unless you defin	e different loa			
Label Prim	nary Load		Load type		DC		ata source:	ΘE
Baseline dat	a							
Month	January	•	14.		Daily Pro	ofile		
Day type	Weekday	-	14					
Day type	TWEEKddy		10	-				
Hour	Load (I	kW) 🖉 🖌	▲ Post (kW)					2
00:00 - 01:0	00	2.000	8 6		57			13
01:00 - 02:0	00	2.000	2					
02:00 - 03:0		2.000	2					
03:00 - 04:0		2.000						
04:00 - 05:0	00	2.000	0	6	12		18	24
05:00 - 06:0	00	7.000			Hour			
06:00 - 07:0	00	7.000	24+					Sea
07:00 - 08:0	00	2.000 📕	24					
08:00 - 09:0	00	2.000	18 1			т	T	T
09:00 - 10:0	00	4.000				1		
10:00 - 11:0	00	4.000	(M) 12					
11:00 - 12:0	00	7.000	oad					
12:00 - 13:0	00	7.000	6					-
13:00 - 14:0	00	7.000						
14:00 - 15:0		8.000		and the second sec			and the second s	

31

Component: Diesel Input

₭ 8kW generator

Sensitivity: [0, 2, 4] kW

to serve	n costs, and hermal load. ,	that the O&M cost i	s expressed in d ne optimal syster	ollars per operating n, HOMER will cor	aintenance (0&M) value in the g hour. Enter a nonzero heat r isider each generator size in t	ecovery ratio if heat	will be recovered from this generator
Fuel	Schedul	e Emissions					
osts Size (kW) 8.000	Capital (\$) 6500	Replacement (\$) 5500	0&M (\$/hr) 0.200		- Sizes to consider - Size (kW) 0.000 2.000	7 6 6	Cost Curve
c.	{	.}	{}	{}	4.000	(\$ 000) to 2 2 1	
Descrip Abbrev	tion Die ation Dsl		Туре	C AC	-	•	2 4 6 8 Size (kW) Capital — Replacement
	(operating n load ratio			_} _}			

Component: Grid Input

Edit Help	
Click Add to add as many rates as necessary. Select a rate Hold the pointer over an element or click Help for more inforr	
tes Emissions Advanced Forecasting	Rate Properties
 Scheduled rates Real time prices ate schedule 	Enter a name for this rate period, and the corresponding power price, sellback rate, and demand rate. Hold the pointer over an element or click Help for more information.
Step 1: Define and select a rate Rate Price Sellback Demand	Label Rate 1 Color All week
(\$/kWh) (\$/kWh) (\$/kW/mo)	Grid newer price (#////h) 015
Rate 1 0.150 0.150 5.000	Sellback rate (\$/kWh) 0.15 {}
	Demand rate (\$/kW/month) 5 {}
Add Remove Edit	This rate applies:
	Months Days Hours
Step 2: Select a time period	Jan-Dec All week 00:00-24:00
All Week Weekdays Weekends	
Step 3: Click on the chart to indicate when the	
selected rate applies.	Help Cancel OK
Net metering	
Net purchases calculated monthly	
C Net purchases calculated annually	
	^{24:00} Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec
	Help Cancel OK

Component: PV Input

₩1kW, \$6900, \$6900, \$0/yr


₭ [0, 2, 4] kW for sensitivity analysis

V Inputs	à		
Enter at least one size and ca hardware, and installation. As	it searches for the optimal sys sets the slope value equal to	able. Include all costs associated with the PV (photovoltaic) system, tem, HOMER considers each PV array capacity in the Sizes to Con- the latitude from the Solar Resource Inputs window. rmation.	including modules, mounting sider table.
Costs Costs Size (kW) Capital (\$) Replacer	nent (\$) 0&M (\$/yr)	Sizes to consider ³⁰	Cost Curve
1.000 6900	6900 0	25	
		4.000 9 15 9 10	
	{.}	{}	
	C DC	— c	1 2 3 4 Size (kW) apital — Replacement
Lifetime (years)	25 {}	Advanced	1
Derating factor (%)	90 {}	Tracking system No Tracking	•
Slope (degrees)	37 {}	Consider effect of temperature	
Azimuth (degrees W of S)	0 {}	Temperature coeff. of power (%/°C)	-0.5
Ground reflectance (%)	20 [}	Nominal operating cell temp. (°C)	47}
		Efficiency at std. test conditions (%)	13 []
		Help C	ancel OK

Component: Wind Turbine Input

- 🔀 Generic 3kW DC
- X Quantity [0,1, 2, 3] for sensitivity analysis

₭ Cost: \$11000, \$7000, \$200/yr



Component: Battery Input

- ₭ Rolls/Surrette 1156 Ah 6V
- **Cost per unit: \$1200, \$1100, \$50/yr**
- 🔀 Quantity [0, 10, 20, 30] for Sensitivity

∺ 1 per string



Choose a battery type and enter at least one quantity and capital cost value hardware, installation, and labor. As it searches for the optimal system, HOM Hold the pointer over an element or click Help for more information.	in the Costs table. Include all costs associated with the battery bank, such as mounting ER considers each quantity in the Sizes to Consider table.
Battery type Surrette 6CS25P 🔹 Details	New Delete
Battery properties	
Manufacturer: Rolls/Surrette	Nominal voltage: 6 V
Website: <u>www.rollsbattery.com</u>	Nominal capacity: 1,156 Ah (6.94 kWh)
	Lifetime throughput: 9,645 kWh
Quantity Capital (\$) Replacement (\$) 0&M (\$/yr) 1 1200 1100 50.00 {} {} {} Advanced	Sizes to consider

Help	Cancel	ОК	36
Неір	Cancel	UK	30

Battery Sizing

10291 - System configuration, battery sizing

Posted by on 22 December 2010 10:28 AM

Is there any particular criteria for sizing of battery storage in HOMER ? How do we size a converter ?

We have found that there is no reliable rule of thumb for determining optimal value of battery autonomy. It depends on many factors, including the daily and seasonal patterns of the load, the daily and seasonal patterns and the intermittency of the relevant renewable resources, the correlation between the load and renewable resources, the fuel price, the size of the backup generator relative to the peak and average load, etc.

So we always rely on HOMER's ability to optimize the size of the battery bank, rather than using some pre-defined size. One possibility is to calculate the number of batteries corresponding to a comfortably long autonomy such as 4 days, and specify a range of possible values from that value down to zero. In truth, I usually rely on trial and error, using HOMER's feedback to revise the battery search space over several runs. This process is much easier in version 2.1 that it was previously because in version 2.1 the information on "winning sizes" appears in the Optimization Inputs window. So you can specify some battery sizes, hit Calculate, then check the bottom half of the Optimization Inputs window to see which battery size was optimal, and use the top half of the window to revise the battery search of the same for any other component as well.

Sizing the converter is somewhat easier that the battery bank because there is a clear upper limit to the converter size, namely the peak load. For example, if the load is AC and its peak value is 6 kW, it is very unlikely that the optimal converter size will exceed 6 kW. I might try a size range such as 6, 4, 3, 2, 1, and 0 kW.

Battery Blues ?

Batteries from Remote


¥ Youtube link: http://www.youtube.com/wat ch?feature=player_detailpag e&v=63mn4iDYL_c

Refer Battery Sizing examples in the lectures on Solar Energy ---- "the number of usable days" requirement/suggestion



Review - Battery Sizing

- ₭ Statistical nature of weather
- No set rules about how best to size battery storage except the cost tradeoff
- Battery system of meeting demand 99% of the time may be 3 times higher in cost than that of meeting 95% of the time.
- Here a number of days of storage to supply a load in the design month [the month with the worst combination of insolation and load]
- **Bays of "usable battery storage**" needed for a stand-alone system
- 🔀 Nominal Battery Storage -- 3 days



39


Review - Battery Sizing

K Nominal rated storage vs. usable storage:

Nominal (C/20, 25°C) battery capacity = $\frac{\text{Usable battery capacity}}{(\text{MDOD})(\text{T, DR})}$ **# Variables**:

MDOD (maximum depth of discharge): <u>0.8 for lead-acid;</u> 0.25 for auto SLI


(T,DR): Discharge Rate Factor under a given Temperature



Review - Battery Sizing Example

- A cabin near Salt Lake City, Utah, has an ac demand of 3000 Wh/day in the winter months. A decision has been made to size the batteries such that a 95% system availability will be provided, and a back-up generator will be kept in reserve to cover the other 5%. The batteries will be kept in a ventilated shed whose temperature may reach as low as −10°C. The system voltage is to be 24 V, and an inverter with overall efficiency of 85% will be used.
- **#** SOLUTION APPROACH
 - \bigtriangleup 1. AC load \rightarrow DC load demand (with 85% inverted efficiency)
 - △ 2. Battery Capacity (Ah)
 - △ 3. Usable storage (Ah) Use the nominal 3 day storage
 - 🗠 4. Nominal capacity (Ah)
 - ⊠ Assumption: 80% deep discharge ← MDOD
 - \boxtimes Assumption: 97% discharge rate \leftarrow (T,DR)
 - 5. Battery Bank Design

Review - SOLUTION - details



Nominal 3-day storage 120 7 3 days = 72 hours 110 Capacity/(Rated Capacity) % P 25 09 02 08 06 001 C/72 Ø C/48 C/20 0.75 C/10 C/5 Usable storage = $147 \text{ Ah/day} \times 3 \text{ day} = 441 \text{Ah}$ 40 30 20 +--30 20 25 30 -20 -10 10 40 0 Battery Temperature (°C) **441** Ah Nominal $(C/20, 25^{\circ}C)$ battery capacity = = **568**Ah (at 24 V) $\overline{0.80 \times 0.97}$ 42

Review - MathCad Solution

Battery Sizing.xmcd Charles Kim 2013

-

A Cabin near Salt Lake City, Utah, has an AC energy demand of 3 kWh per day in the winter months. With a battery system, a 95% availability will be provided, while a back-up generator will be kept to cover the other 5%. The battery system will be kept in a ventilated shed where the temperatue may go as low as - 10 C degrees. The system voltage is 24 V, and an inverter efficiency is 85%. Assume 80% deep discharge (MDOD) and 97 % discharge rate (T,DR)

40.7500° N, 111.8833° W

Salt Lake City, Coordinates



(Q) Calculate the size of the battery system.

MDOD := 0.8 TDR := 0.97 Eac := 3 kWh / day D2A := 0.85 Inverter Efficiency Bvolt := 24 Battery System Voltage

SOLUTION

1. DC energy demand (Edc):

$$Edc := \frac{Eac}{D2A} = 3.5294 \qquad kWh \ /day$$

2. Expression of the energy demand in terms of Amp-Hour per day. Remember that Energy=Power*Time = V*A*time, ==> A*hour = Wh/V

$$AH := \frac{Edc \times 1000}{Bvolt} = 147.0588 \quad Ah/day$$

Review- MathCad Solution


- 3. Find the usable storage Ah at -10 C degree (use the graph)
 - a. Peak-Sun-Hour information
- b. Find the # of days of usuable storage(Dus) --- Use nominal 3-day storage

Dus := 3 days

c. Now we calculate the Usuable Storage Amp-Hour (AHus)

AHus := AH × Dus = 441.1765 Ah

d. Finally, the nominal (C/20, 25 C) capacity:



MDOD = 0.8000 Nominal 3-day storage TDR = 0.9700

 $MDOD \times TDR = 0.7760$

 $AHnorm := \frac{AHus}{MDOD \times TDR} \qquad Ah$


AHnorm = 568.5264

and the second s

Review - Battery Selection - Example

∺ 871 Ah @ 24V

BATTERY	Voltage	Weight (lbs)	Ah @ C/20	Ah @ C/100
Concorde PVX 5040T	2	57	495	580
Trojan T-105	6	62	225	250
Trojan L16	6	121	360	400
Concorde PVX 1080	12	70	105	124
Surette 12CS11PS	12	272	357	503



Component: Converter Input

∺ 10kW

- ₭ Cost: \$12500, \$12500, \$100/yr
- [0, 2, 4, 6, 8kW] for sensitivity analysis
- ₭ Inversion Efficiency 90%
- ₭ Rectification Efficiency 85%

both. Enter a the opt inverte	erter is requi t least one s imal system, r capacity.	ize and capital cost	value in the Co each converter	ists table. Include all capacity in the Size	costs associated with the con-	verter, such a	werter (DC to AC), rectifier (AC to DC), or as hardware and labor. As it searches for to converter size or capacity refer to
osts					Sizes to consider —	23	
Size (kW)	Capital (\$)	Replacement (\$)	0&M (\$/yr)	-	Size (kW)	14	Cost Curve
10.000	12500	12500	100		0.000	/ 12-	
					2.000	(\$ 10 - 8 s	
∨erter inpu	{.	}	{}	{.}	6.000	000 000 000 00 0 0 0 0 0 0 0	0 2 4 6 8 10 Size (KW)
Lifetim	e (years)		20	{.}	-		- Capital - Replacement
Efficier	ncy (%)		90	{}			
		porsto cimultan	oouely with a	an AC generator			
l≁ m∧∈	aner carru	perate simultan	eousiy with a	an AC generator			
ectifier inp	uts						
Capac	ity relative	to inverter (%)	100	{·}}	-		
- Efficier	~ . (%/)		85				
Efficier	icy (~)		1 05	<u>{.}</u>			1
						Help	Cancel OK

Other: Economics

- ₭ Real annual interest: 8%
- **#** Project Lifetime: 25 years
- ₭ System fixed cost: \$6000
 - It represents balance of system and distribution system costs that cannot be allocated to a specific component.

Econom	nic Inputs		-	
File E	dit Help			
ŝ	HOMER applies the economic inputs to each system it si present cost. Hold the pointer over an element name or click Help for n		te the sy	vstem's net
	Annual real interest rate (%)	3	{}	*
	Project lifetime (years)	25	<i>{}</i>	*
	System fixed capital cost (\$)	6000	{}	¥
	System fixed O&M cost (\$/yr)	0	{}	
	Capacity shortage penalty (\$/kWh)	0	{}	
	Help	Cance		ОК

Other: System Control

Simulation Time Step: 1 hr (60 min)

X Dispatch Strategies:	
Ioad following	
Cycle charging	
⊠Charge state set point: 80%	
System Control Inputs	
File Edit He	
The system control inputs define how HOMER models the operation of the battery bank and generators. The dispatch strategy determines how the system charges the battery bank. Hold the pointer over an element name or click Help for more information.	
Simulation	
Dispatch strategy ✓ Load following ✓ Cycle charging ✓ Apply setpoint state of charge (%) 80 {}	
Generator control Allow systems with multiple generators Allow multiple generators to operate simultaneously Allow systems with generator capacity less than peak load	
	18

Other: Constraints Input

- Max annual capacity storage: 0% [0.0, 0.1] for sensitivity analysis
- ₭ Operating Reserve: 10% of hourly load

Constraints		
File Edit Help		
Constraints are conditions that systems must meet to be feasible. Infeasible systems do no reserve provides a margin to account for intra-hour deviation from the hourly average of the margin for each hour based on the operating reserve inputs. Hold the pointer over an element name or click Help for more information.		abula 🖲 Gr
	Sensitivity Values	-
Maximum annual capacity shortage (%) 0 {2} Minimum renewable fraction (%) 0 {}	Variable: Maximum Annual Capacity Units: %	Shortage
Operating reserve	Link with: <none></none>	•
As percent of load		0
Hourly load (%) 10 {}	2 0.1	Clear
Annual peak load (%)	3 4	
As percent of renewable output	5	
Solar power output (%) 25 {}	7	
Wind power output (%) 50 {}	8 9	

Emission Input (Optional)

∺CO2 Emission Limit

sions Inputs		
Edit Help		
Costs resulting from emissions penalties appear as systems that excells the specified emissions limits.	'Other O&M cost'. HOMER disca	
Hold the pointer over an element or click Help for i	more information.	COE Ren. Diesel GEN /kW Frac. (L) (hrs)
Emissions penalties		1.254 0.13 7,350 8,7 1.259 0.00 7,711 8,7
Carbon dioxide (\$/t)	3 {4}	1.470 0.15 7,310 8,7
Carbon monoxide (\$/t)	0 {}	Sensitivity Values
Unburned hydrocarbons (\$/t)	0 {}	Variable: Maximum CO2 Emissions
Particulate matter (\$/t)	0 {}	Units: kg/yr
Sulfur dioxide (\$/t)	3 {}	Link with: <none></none>
Nitrogen oxides (\$/t)	3 {}	Values: 1 10000 Clear
Limits on emissions		2 20000 3 30000
🔽 Carbon dioxide (kg/yr)	10000	4 40000 5
🦳 Carbon monoxide (kg/yr)	0 {}	6 7
🔲 Unburned hydrocarbons (kg/yr)	0 {}	8
🦳 Particulate matter (kg/yr)	0 {}	9 10
🔲 Sulfur dioxide (kg/yr)	0 {}	
🔲 Nitrogen oxides (kg/yr)	0 {}	
Holp		Help Cancel OK

Simulation

Calculate: Optimization Result


Categorized


Sensitivity Results Opti	mizatio	on Resi	ults											
Sensitivity variables														
Wind Speed (m/s) 3	• [Diesell	Price (\$/L	.) 0.3	-	Max. A	nnual Capac	ity Shortage	(%) 0 🔹	·				
Double click on a system	below	for sim	nulation r	esults.						Categori	iz 🔿 🤇	Overal	Export	Details
	G3		S6CS2				Initial	Operating	Total			Capacity		Dsl
		(kW)		(kW)	Strgy	(kW)	Capital	Cost (\$/yr)	NPC	(\$/kW	Frac.	Shorta	(L)	(hrs)
4 602		2	10	2	CC	1	\$ 22,125	3,152	\$ 55,776	0.409	0.00	0.00	2,904	4,400
1447 00 ₪ 2 2		2	10	2	CC	1	\$ 35,925	2,670	\$ 64,428	0.472	0.22	0.00	2,031	3,077
≮&¦©⊠⊠	1	2	10	2	CC	1	\$ 33,125	3,401	\$ 69,434	0.509	0.06	0.00	2,646	4,009
1447/▲७@図 2	1	2	10	2	CC	1	\$ 46,925	2,927	\$ 78,175	0.573	0.28	0.00	1,796	2,721

Overall

Sens	itivity Results	, Optir	nizatio	on Res	ults											
Sens	itivity variable	es —														
Wind Speed (m/s) 3 💌 Diesel Price (\$/L) 0.3 💌 Max. Annual Capacity Shortage (%) 0 💌																
Doub	Double click on a system below for simulation results.												Details			
 	′≴≿⊡⊠	PV	G3		S6CS2			Grid	Initial	Operating	Total	COE		Capacity		Dsl
		(kW)		(kW)			Strgy	(kW)	Capital	Cost (\$/yr)		1.		Shortage		(hrs)
「不	è 🖻 🛛			2	10	2	CC	1	\$ 22,125	3,152	\$ 55,776	0.409	0.00	0.00	2,904	4,400
イ	è 🖻 🖂			2	10	4	CC	1	\$ 24,625	3,204	\$ 58,824	0.431	0.00	0.00	2,921	4,426
木ዋ	′ ေညာံများစားစား	2		2	10	2	CC	1	\$ 35,925	2,670	\$ 64,428	0.472	0.22	0.00	2,031	3,077
「本」	è 🖻 🖂			2	10	6	CC	1	\$27,125	3,613	\$65,693	0.482	0.00	0.00	4,660	7,061
本甲	′ ေညာံများစားစား	2		4	10	2	LF	1	\$ 37,550	2,917	\$ 68,686	0.504	0.16	0.00	4,883	3,699
1 ⊀	è 🖻 🖂			2	10	8	CC	1	\$ 29,625	3,693	\$ 69,048	0.506	0.00	0.00	4,929	7,468
オ	\$\$````` ■ 🖾		1	2	10	2	CC	1	\$ 33,125	3,401	\$ 69,434	0.509	0.06	0.00	2,646	4,009
本ዋ	′ ေဲမာ 🖾	2		2	10	4	CC	1	\$ 38,425	3,107	\$ 71,592	0.525	0.17	0.00	3,708	5,618
木中	′ 👌 🖻 🖾	2		4	10	4	LF	1	\$ 40,050	3,002	\$ 72,101	0.529	0.16	0.00	4,723	3,578
ーズ	🎄 🏷 🖻 🕅		1	2	10	4	CC	1	\$ 35.625	3.450	\$ 72.454	0.531	0.06	0.00	2.660	4.031

Result: Electrical & Cash Flow






52


Sensitivity Analysis


₭ Wind Speed (x) vs. Diesel Price with 0% capacity shortage



Sensitivity Analysis


Biesel Price(x) vs. Wind Speed (y) with 0.05% capacity shortage






Surface Plot View

PV Array Capacity




Surface Plot View

₭ Wind Power



Surface Plot View

Grid Purchase



What we have learned so far

#HOMER

Editing an example code
 Resources and components
 Simulation ("calculate") and Optimization
 Result interpretation
 Creating a design of code
 For your system
 Resources and components
 Simulation and optimization
 We are ready to do something more our own !!

Team Project (Now)

Team Project Demonstration/Presentation (Tomorrow)